

SWIMMING POOL OFFICIAL INSPECTION REPORT
GLENN COUNTY ENVIRONMENTAL HEALTH

225 N. Tehama Street, Willows, CA 95988
 Phone (530) 934-6102 FAX (530) 934-6103

Name of Facility / DBA: <u>VILLA COURT TOWNHOMES</u>			Inspection Date: <u>5/9/22</u>			
Address: <u>127 VILLA COURT, WILLOWS, CA</u>			Reinspection Date (one or after): <u>*POOL IS CLOSED</u> <small>(Reinspections are subject to fees)</small>			
Owner/Permittee: <u>VILLA COURT TOWNHOMES</u>		Phone Number:		Inspection Time: <u>3:30</u>	Permit Expiration Date:	
Pool Type: <input checked="" type="checkbox"/> Swimming Pool <input type="checkbox"/> Spa Pool <input type="checkbox"/> Wading Pool <input type="checkbox"/> Interactive Water Feature <input type="checkbox"/> Other			Service: <input type="checkbox"/> Routine Inspection <input type="checkbox"/> Reinspection <input checked="" type="checkbox"/> Complaint <input type="checkbox"/> Construction/Pre-Opening <input type="checkbox"/> Other			
pH: <u>NOT TESTED</u>	Free Chlorine:	Combined Chlorine:	Cyanuric Acid:	Flow Rate:	Temperature:	Other:

Applicable Laws & Regulations: California Health & Safety Code § 116025 et. seq.; California Code of Regulations Title 24, Chapter 31 & Title 22, Chapter 20

<p>Pool Construction</p> <p>1. <input type="checkbox"/> Pool Shell</p> <p>2. <input type="checkbox"/> Bottom & Sides</p> <p>3. <input type="checkbox"/> Decks & Coping</p> <p>4. <input type="checkbox"/> Diving Boards</p> <p>5. <input type="checkbox"/> Depth Markers</p> <p>6. <input type="checkbox"/> Ladders/Steps/Railings</p> <p>7. <input type="checkbox"/> Underwater Lighting & Electrical</p> <p>Recirculation Equipment</p> <p>8. <input type="checkbox"/> Filters</p> <p>9. <input type="checkbox"/> Pumps</p> <p>10. <input type="checkbox"/> Flowmeter</p> <p>11. <input type="checkbox"/> Pressure/Vacuum Gauges</p> <p>12. <input type="checkbox"/> Skimmers & Gutters</p> <p>13. <input type="checkbox"/> Pipes & Fittings</p> <p>14. <input type="checkbox"/> Chemical Feeders</p> <p>15. <input type="checkbox"/> Water Supply/Backflow Prevention</p>	<p>Water Quality</p> <p>16. <input type="checkbox"/> pH</p> <p>17. <input type="checkbox"/> Chlorine/Bromine</p> <p>18. <input type="checkbox"/> Cyanuric Acid</p> <p>19. <input checked="" type="checkbox"/> Debris in Pool</p> <p>20. <input checked="" type="checkbox"/> Water Clarity</p> <p>21. <input type="checkbox"/> Temperature</p> <p>22. <input type="checkbox"/> Flow Rate/Turnover</p> <p>Safety Equipment</p> <p>23. <input type="checkbox"/> Gates/Enclosure</p> <p>24. <input type="checkbox"/> Drain Covers</p> <p>25. <input type="checkbox"/> Anti-Entrapment Shutoff</p> <p>26. <input type="checkbox"/> Rescue Pole</p> <p>27. <input type="checkbox"/> Life Ring</p> <p>28. <input type="checkbox"/> Safety Signs</p> <p>29. <input type="checkbox"/> First Aid Kit</p> <p>30. <input type="checkbox"/> Chlorine Gas Safety</p>	<p>General Facilities</p> <p>31. <input type="checkbox"/> Exterior Lighting</p> <p>32. <input type="checkbox"/> Indoor Ventilation</p> <p>33. <input type="checkbox"/> Restrooms & Toilets</p> <p>34. <input type="checkbox"/> Handwash Sinks</p> <p>35. <input type="checkbox"/> Dressing Room</p> <p>36. <input type="checkbox"/> Showers</p> <p>37. <input type="checkbox"/> Drinking Fountains</p> <p>Miscellaneous</p> <p>38. <input type="checkbox"/> Chemical Test Kits</p> <p>39. <input type="checkbox"/> Chemical Testing Frequency</p> <p>40. <input type="checkbox"/> Record Keeping</p> <p>41. <input type="checkbox"/> Lifeguards</p> <p>42. <input type="checkbox"/> Communicable Disease Control</p> <p>43. <input checked="" type="checkbox"/> Site Supervision & Control</p> <p>44. <input type="checkbox"/> General Sanitation</p> <p>45. <input type="checkbox"/> Other:</p>
--	--	--

Comments:

*** THE POOL HAS BEEN CLOSED BY GLENN COUNTY ENVIRONMENTAL HEALTH DUE TO THE FOLLOWING:

(19) + (20) THE POOL IS NOT BEING MAINTAINED AND IS GREEN.

(43) THE GATE & ENCLOSURE SHALL BE LOCKED UP AND SECURITY MEASURES SHALL BE TAKEN TO PREVENT PEOPLE FROM ACCESSING THE HAZARDOUS POOL.

*** IF/WHEN THE POOL IS TO BE RE-OPENED, CONTACT GLENN COUNTY ENVIRONMENTAL HEALTH FOR AN OPENING INSPECTION.

Received By:	REHS: <u>ANDREW PETYO</u>
--------------	---------------------------