

SWIMMING POOL OFFICIAL INSPECTION REPORT

GLENN COUNTY ENVIRONMENTAL HEALTH

247 North Villa Avenue, Willows, CA 95988
Phone: (530) 934-6102 • Fax: (530) 934-6103

Page 1 of 1

Name of Facility/DBA: <u>Painewood Apartments Spa</u>				Inspection Date: <u>6/25/19</u>			
Address: <u>745 Painewood Dr, Orland, CA 95963</u>				Reinspection Date (on or after): <u>By Dept.</u> <small>(Reinspections are subject to fees)</small>			
Owner/Permittee: <u>Orland Pacific Associates</u>			Phone Number: <u>865-1313</u>		Inspection Time: <u>1:25pm</u>	Permit Expiration Date:	
Pool Type: <input type="checkbox"/> Swimming Pool <input checked="" type="checkbox"/> Spa Pool <input type="checkbox"/> Wading Pool <input type="checkbox"/> Interactive Water Feature <input type="checkbox"/> Other				Service: <input checked="" type="checkbox"/> Routine Inspection <input type="checkbox"/> Reinspection <input type="checkbox"/> Complaint <input type="checkbox"/> Construction/Pre-Opening <input type="checkbox"/> Other			
pH: <u>8.4</u>	Free Chlorine: <u>0.4 ppm</u>	Combined Chlorine: <u>0.4 ppm</u>	Cyanuric Acid: <u>29 ppm</u>	Flow Rate: <u>Could not determine</u>	Temperature: <u>98° F</u>	Other: <u>CA-102 CA-90</u>	
Applicable Laws & Regulations: <u>California Health & Safety Code § 116025 et. seq., California Code of Regulations Title 24, Chapter 31 & Title 22, Chapter 20</u>							

Pool Construction 1. <input type="checkbox"/> Pool Shell 2. <input type="checkbox"/> Bottom & Sides 3. <input type="checkbox"/> Decks & Coping 4. <input type="checkbox"/> Diving Boards 5. <input type="checkbox"/> Depth Markers 6. <input type="checkbox"/> Ladders/Steps/Railings 7. <input type="checkbox"/> Underwater Lighting & Electrical Recirculation Equipment 8. <input type="checkbox"/> Filters 9. <input type="checkbox"/> Pumps 10. <input checked="" type="checkbox"/> Flowmeter 11. <input type="checkbox"/> Pressure/Vacuum Gauges 12. <input checked="" type="checkbox"/> Skimmers & Gutters 13. <input type="checkbox"/> Pipes & Fittings 14. <input type="checkbox"/> Chemical Feeders 15. <input type="checkbox"/> Water Supply/Backflow Prevention	Water Quality 16. <input checked="" type="checkbox"/> pH 17. <input checked="" type="checkbox"/> Chlorine/Bromine 18. <input type="checkbox"/> Cyanuric Acid 19. <input type="checkbox"/> Debris in Pool 20. <input type="checkbox"/> Water Clarity 21. <input type="checkbox"/> Temperature 22. <input type="checkbox"/> Flow Rate/Turnover Safety Equipment 23. <input type="checkbox"/> Gates/Enclosure 24. <input type="checkbox"/> Drain Covers 25. <input type="checkbox"/> Anti-Entrapment Shutoff 26. <input type="checkbox"/> Rescue Pole 27. <input type="checkbox"/> Life Ring 28. <input type="checkbox"/> Safety Signs 29. <input type="checkbox"/> First Aid Kit 30. <input type="checkbox"/> Chlorine Gas Safety	General Facilities 31. <input type="checkbox"/> Exterior Lighting 32. <input type="checkbox"/> Indoor Ventilation 33. <input type="checkbox"/> Restrooms & Toilets 34. <input type="checkbox"/> Handwash Sinks 35. <input type="checkbox"/> Dressing Rooms 36. <input type="checkbox"/> Showers 37. <input type="checkbox"/> Drinking Fountains Miscellaneous 38. <input type="checkbox"/> Chemical Test Kits 39. <input type="checkbox"/> Chemical Testing Frequency 40. <input type="checkbox"/> Record Keeping 41. <input type="checkbox"/> Lifeguards 42. <input type="checkbox"/> Communicable Disease Control 43. <input type="checkbox"/> Site Supervision & Control 44. <input type="checkbox"/> General Sanitation 45. <input type="checkbox"/> Other:
---	---	---

Comments:

* Pool & Spa are closed! Do not reopen without approval from our office.

Critical Violations (Closure Violations)

16) Maintain pH between 7.2 - 7.8. Measured pH at 8.4.

17) Maintain ~~between~~ free available chlorine between 3.0 - 10.0 ppm. Measured 0.4 ppm of free chlorine.

Other Violations

10) Repair/replace inoperable flow meter.

2) Replace missing skimmer weir.

Received By: <u>[Signature]</u>	REHS: <u>John H. Wells</u>
---------------------------------	----------------------------