

SWIMMING POOL OFFICIAL INSPECTION REPORT

GLENN COUNTY ENVIRONMENTAL HEALTH

225 N. Tehama Street, Willows, CA 95988
Phone (530) 934-6102 FAX (530) 934-6103

Page 1 of 1

Name of Facility / DBA: PAIGEWOOD APARTMENTS POOL		Inspection Date: 8/30/23	
Address: 745 PAIGEWOOD DRIVE, ORLAND, CA		Reinspection Date (one or after): NEXT INSPECTION <small>(Reinspections are subject to fees)</small>	
Owner/Permittee: ORLAND PACIFIC ASSOCIATES	Phone Number: 916-1313	Inspection Time: 9:00	Permit Expiration Date: -
Pool Type: <input checked="" type="checkbox"/> Swimming Pool <input type="checkbox"/> Spa Pool <input type="checkbox"/> Wading Pool <input type="checkbox"/> Interactive Water Feature <input type="checkbox"/> Other	Service: <input checked="" type="checkbox"/> Routine Inspection <input type="checkbox"/> Reinspection <input type="checkbox"/> Complaint <input type="checkbox"/> Construction/Pre-Opening <input type="checkbox"/> Other		
pH: 7.5	Free Chlorine: 14.28 PPM	Combined Chlorine: -	Cyanuric Acid: 12 PPM
Flow Rate: UNABLE TO TEST		Temperature: -	Other: -

Applicable Laws & Regulations: California Health & Safety Code § 116025 et. seq.; California Code of Regulations Title 24, Chapter 31 & Title 22, Chapter 20

Pool Construction 1. <input type="checkbox"/> Pool Shell 2. <input type="checkbox"/> Bottom & Sides 3. <input type="checkbox"/> Decks & Coping 4. <input type="checkbox"/> Diving Boards 5. <input type="checkbox"/> Depth Markers 6. <input type="checkbox"/> Ladders/Steps/Railings 7. <input type="checkbox"/> Underwater Lighting & Electrical	Water Quality 16. <input type="checkbox"/> pH 17. <input type="checkbox"/> Chlorine/Bromine 18. <input type="checkbox"/> Cyanuric Acid 19. <input type="checkbox"/> Debris in Pool 20. <input type="checkbox"/> Water Clarity 21. <input type="checkbox"/> Temperature 22. <input type="checkbox"/> Flow Rate/Turnover	General Facilities 31. <input type="checkbox"/> Exterior Lighting 32. <input type="checkbox"/> Indoor Ventilation 33. <input type="checkbox"/> Restrooms & Toilets 34. <input type="checkbox"/> Handwash Sinks 35. <input type="checkbox"/> Dressing Room 36. <input type="checkbox"/> Showers 37. <input type="checkbox"/> Drinking Fountains
Recirculation Equipment 8. <input type="checkbox"/> Filters 9. <input type="checkbox"/> Pumps 10. <input checked="" type="checkbox"/> Flowmeter 11. <input checked="" type="checkbox"/> Pressure/Vacuum Gauges 12. <input type="checkbox"/> Skimmers & Gutters 13. <input checked="" type="checkbox"/> Pipes & Fittings 14. <input type="checkbox"/> Chemical Feeders 15. <input type="checkbox"/> Water Supply/Backflow Prevention	Safety Equipment 23. <input type="checkbox"/> Gates/Enclosure 24. <input type="checkbox"/> Drain Covers 25. <input type="checkbox"/> Anti-Entrapment Shutoff 26. <input type="checkbox"/> Rescue Pole 27. <input type="checkbox"/> Life Ring 28. <input checked="" type="checkbox"/> Safety Signs 29. <input type="checkbox"/> First Aid Kit 30. <input type="checkbox"/> Chlorine Gas Safety	Miscellaneous 38. <input type="checkbox"/> Chemical Test Kits 39. <input type="checkbox"/> Chemical Testing Frequency 40. <input type="checkbox"/> Record Keeping 41. <input type="checkbox"/> Lifeguards 42. <input type="checkbox"/> Communicable Disease Control 43. <input type="checkbox"/> Site Supervision & Control 44. <input type="checkbox"/> General Sanitation 45. <input checked="" type="checkbox"/> Other:

Comments: CORRECT THE FOLLOWING:

(10) REPAIR OR REPLACE FLOW METER ON POOL CIRC. EQUIPMENT

(11) REPAIR OR REPLACE NON-OPERABLE PRESSURE GAUGES ON POOL CIRC EQUIPMENT

(13) ALL PLUMBING SHALL HAVE ARROWS INDICATING DIRECTION OF FLOW.

(28) REPLACE WORN OR FADED SAFETY SIGNS.

(45) ~~REPAIR~~ ONE OF THE U.C.B DRAIN COVERS HAVE BEEN REPLACED IN THE POOL WITHOUT BENEFIT OF PLAN CHECK BY G.C.E.H. SUBMIT PAPERWORK FOR DRAIN COVERS TO OUR DEPARTMENT. REPEAT VIOLATION!

(45) ALL CHANGES TO THE POOL MUST BE PLAN CHECKED AND APPROVED BEFORE INSTALLATION BY GLENN CO. (NEW CHLORINATOR). ~~REPEAT VIOLATION~~

Received By: [Signature] REHS: Andrew A. Pardo