

# SWIMMING POOL OFFICIAL INSPECTION REPORT

## GLENN COUNTY ENVIRONMENTAL HEALTH

247 North Villa Avenue, Willows, CA 95988

Phone: (530) 934-6102 • Fax: (530) 934-6103

Page 1 of 1

Name of Facility/DBA: <b>Parkwood Apartments Spa</b>		Inspection Date: <b>8/15/18</b>	
Address: <b>745 Parkwood Dr Orland CA 95963</b>		Reinspection Date (on or after): <b>Next Inspection</b> <small>(Reinspections are subject to fees)</small>	
Owner/Permittee: <b>Orland Pacific Associates</b>		Phone Number: <b>865-1313</b>	Inspection Time: <b>11:30am</b>
Pool Type: <input type="checkbox"/> Swimming Pool <input checked="" type="checkbox"/> Spa Pool <input type="checkbox"/> Wading Pool <input type="checkbox"/> Interactive Water Feature <input type="checkbox"/> Other		Service: <input checked="" type="checkbox"/> Routine Inspection <input type="checkbox"/> Reinspection <input type="checkbox"/> Complaint <input type="checkbox"/> Construction/Pre-Opening <input type="checkbox"/> Other	
pH: <b>7.2</b>	Free Chlorine: <b>7.1 ppm</b>	Combined Chlorine: <b>0.5 ppm</b>	Cyanuric Acid: <b>99 ppm</b>
Flow Rate: <b>could not determine</b>		Temperature: <b>~90°F</b>	Other: <b>-</b>
Applicable Laws & Regulations: California Health & Safety Code § 116025 et. seq., California Code of Regulations Title 24, Chapter 31 & Title 22, Chapter 20			

### Pool Construction

1.  Pool Shell
2.  Bottom & Sides
3.  Decks & Coping
4.  Diving Boards
5.  Depth Markers
6.  Ladders/Steps/Railings
7.  Underwater Lighting & Electrical

### Water Quality

16.  pH
17.  Chlorine/Bromine
18.  Cyanuric Acid
19.  Debris in Pool
20.  Water Clarity
21.  Temperature
22.  Flow Rate/Turnover

### General Facilities

31.  Exterior Lighting
32.  Indoor Ventilation
33.  Restrooms & Toilets
34.  Handwash Sinks
35.  Dressing Rooms
36.  Showers
37.  Drinking Fountains

### Recirculation Equipment

8.  Filters
9.  Pumps
10.  Flowmeter
11.  Pressure/Vacuum Gauges
12.  Skimmers & Gutters
13.  Pipes & Fittings
14.  Chemical Feeders
15.  Water Supply/Backflow Prevention

### Safety Equipment

23.  Gates/Enclosure
24.  Drain Covers
25.  Anti-Entrapment Shutoff
26.  Rescue Pole
27.  Life Ring
28.  Safety Signs
29.  First Aid Kit
30.  Chlorine Gas Safety

### Miscellaneous

38.  Chemical Test Kits
39.  Chemical Testing Frequency
40.  Record Keeping
41.  Lifeguards
42.  Communicable Disease Control
43.  Site Supervision & Control
44.  General Sanitation
45.  Other:

### Comments:

② Replace the missing skimmer weirs.

\* Flow rate was not checked; could not access pump/filter area.

Recommendation: partially drain spa to lower cyanuric acid to 30-50 ppm.

Received By: **[Signature]**

REHS: **John H. Wells**